



ADDENDUM

Public Building Commission of Chicago | Richard J. Daley Center | 50 West Washington Street, Room 200 | Chicago, Illinois 60602 | (312) 744-3090 | pbccchicago.com

ADDENDUM NO.: 02
PROJECT NAME: Dore Elementary School New Construction Project
PROJECT NO.: 05025
CONTRACT NO.: C1577R
DATE OF ISSUE: July 27, 2017

NOTICE OF CHANGES, MODIFICATIONS, OR CLARIFICATIONS TO CONTRACT DOCUMENTS

The following changes, modifications, or clarifications are hereby incorporated and made an integral part of the Contract Documents. Unless clearly expressed otherwise by this Addendum, all terms and conditions defined in the original Contract Documents shall continue in full force and effect and shall have the same meaning in this Addendum. Issued Addenda represent responses/clarifications to various inquiries. Contractors shall be responsible for including all associated labor/material costs in its bid. Drawings/specifications corresponding to inquiry responses will be issued with the Issue for Construction Documents, upon issuance of building permit.

ITEM NO. 1: CHANGE TO KEY DATES

None.

ITEM NO. 2: REVISIONS TO BOOK 1 – PBC INSTRUCTIONS TO BIDDERS

None.

ITEM NO. 3: REVISIONS TO BOOK 2 – PBC STANDARD TERMS AND CONDITIONS

None.

ITEM NO. 4: REVISIONS TO BOOK 3 – TECHNICAL SPECIFICATIONS

None.

ITEM NO. 5: REVISIONS TO DRAWINGS

None.

ITEM NO. 6: REQUESTS FOR INFORMATION

RFI-1.

Question: There is some conflict between the specs and drawings on Dimensional letters. The spec says the material of the dimensional letters should be cast aluminum. Though in drawings it states the material should be stainless steel. Please confirm the material to be used on the dimensional letters.

Response: Dimensional letters to be cast aluminum per specifications. Size(s) as indicated on drawings. Pin-mounted installation (as indicated on drawings) per specifications.

List of Attachments and Drawings:

(Available at Springer Blueprint Online Planroom: <https://www.springerblueprint.com/>)

This Addendum includes the following attached Specifications and/or Documents:

1. None.

This Addendum includes the following attached Drawings:

1. None.

END OF ADDENDUM NO. 02