PUBLIC BUILDING COMMISSION OF CHICAGO MICHAEL REESE HOSPITAL ABATEMENT AND DEMOLITION AMBIENT AIR QUALITY MONITORING RESULTS

WEEK OF: March 14, 2011

		Monday March 14			Tuesday March 15			Wednesday March 16			Thursday March 17			Friday March 18		
Sample Location		Respirable Dust (µg/m³)ª	Asbestos (s/cc) ^b	Lead (µg/m³)	Respirable Dust (µg/m³)	Asbestos (s/cc)	Lead (µg/m³)	Respirable Dust (µg/m³)	Asbestos (s/cc)	Lead (μg/m³)	Respirable Dust (µg/m³)	Asbestos	Lead (µg/m³)	Respirable Dust (µg/m³)	Asbestos (s/cc)	Lead (µg/m³)
Perimeter	North	43	(3/00)	(µу/ш)	28.2	(3/00)	(рулп)	82.7	(3/00)	(рулт)	53.4	(3/00)	(рулп)	46	(3/00)	(μg////
	East	21.2			23.5			55.9			35.9*			40.5		
	South	45.1			41.9			39.8			63.9			40.9		
	West	40.1			28			32.3			14.8			44.6*		
Sensitive Receptors	Advocate Health	20.2			2.53			19.8			11.4			21		
	Drake Elementary School	15.6			23.8			52.7			44.6			37.3		
	Prairie Shores Apartments	10.5			4.89			15.6			40.9			44.8		
	Pershing Elementary School	51			37.1			70.4			66.6*			73.7		

Comments: *Damaged filter

Notes: $a - \mu g/m^3$ denotes micrograms per cubic meter; b - s/cc denotes structures per cubic centimeter Target Levels: Respirable Dust - 150 $\mu g/m^3$, Asbestos - 0.02 s/cc, Lead 1.5 $\mu g/m^3$ (when expressed as U.S. EPA standards the respirable dust is a 24-hour average and the lead is a quarterly average measured 24 hours per day)