



## ADDENDUM

Public Building Commission of Chicago | Richard J. Daley Center | 50 West Washington Street, Room 200 | Chicago, Illinois 60602 | (312) 744-3090 | pbochicago.com

**ADDENDUM NO.:** 05  
**PROJECT NAME:** FPDCC Metal Buildings – McGinnis Field Station  
**PROJECT NO.:** 15070  
**CONTRACT NO.:** C1613  
**DATE OF ISSUE:** February 4, 2025

### NOTICE OF CHANGES, MODIFICATIONS, OR CLARIFICATIONS TO CONTRACT DOCUMENTS

The following changes, modifications, or clarifications are hereby incorporated and made an integral part of the Contract Documents. Unless clearly expressed otherwise by this Addendum, all terms and conditions defined in the original Contract Documents shall continue in full force and effect and shall have the same meaning in this Addendum. Issued Addenda represent responses/clarifications to various inquiries. Contractors shall be responsible for including all associated labor/material costs in its bid. Drawings/specifications corresponding to inquiry responses will be issued with the Issue for Construction Documents, upon issuance of building permit.

**ITEM NO. 1: CHANGE TO KEY DATES**

None.

**ITEM NO. 2: REVISIONS TO BOOK 1 – PBC INSTRUCTIONS TO BIDDERS**

None.

**ITEM NO. 3: REVISIONS TO BOOK 2 – PBC STANDARD TERMS AND CONDITIONS**

None.

**ITEM NO. 4: REVISIONS TO BOOK 3 – TECHNICAL SPECIFICATIONS/REPORTS**

None.

**ITEM NO. 5: REVISIONS TO DRAWINGS**

None.

**ITEM NO. 6: REQUESTS FOR INFORMATION**

**RFI-1.**

**Question:** Can you please clarify Alternate 1 that was issued in Addendum #3? Is this alternate to provide concrete encasement of the secondary electrical service (from new transformer to the new metal building), or concrete encasement of the primary ComEd feed?

**Response:** [Alternate 1 for Concrete encasement is for the primary ComEd Feed. More specifically, from the Pole at 110th Ave. \(at the project entrance\) to the New Transformer.](#)

This Addendum includes the following attached Specifications and/or Documents:

1. None.

This Addendum includes the following attached Drawings:

2. None.

**END OF ADDENDUM NO. 05**